



NOTES:

1. WHEN VALVE IS NOT LOCATED IN PAVEMENT PLACE 1 GREEN RAISED PAVEMENT MARKER IN ADJACENT ROADWAY.
2. OPERATOR EXTENSION SHAFT SHALL BE PROVIDED WHEN OPERATING NUT IS MORE THAN 24" BELOW TOP OF VALVE BOX.
3. PVC PIPE AND DUCTILE IRON PIPE ARE ACCEPTABLE FOR VALVE BOX RISER WITH PROPER BEDDING.

DATE: 08/24

DRAWN: KHA



CITY OF MARGATE, FLORIDA  
DEPARTMENT OF ENVIRONMENTAL  
AND ENGINEERING SERVICES

**GATE OR PLUG VALVE**

**WW-9**