



NOTE:

1. MINIMUM COVER IS 30" FOR D.I.P. AND 36" FOR P.V.C.
2. WHEREVER POSSIBLE DEFLECTION OF THE PIPE WILL BE USED TO AVOID EXISTING OBSTRUCTIONS. THIS CROSSING SHALL BE USED ONLY WHEN ORDERED BY THE INSPECTOR AND APPROVED BY THE ENGINEER.

DATE: 08/24

DRAWN: KHA



CITY OF MARGATE, FLORIDA
DEPARTMENT OF ENVIRONMENTAL
AND ENGINEERING SERVICES

SPECIAL UTILITY CROSSING

G-5