



NOTES:

1. ALL JOINTS TO BE RESTRAINED BY APPROVED METHODS.
2. IF CONNECTION IS PRIOR TO FDEP CLEARANCE THEN A SECOND VALVE WITH VENT IS REQUIRED.
3. ALTERNATE OPTIONS MAY BE USED AS NECESSARY.

DATE: 03/24

DRAWN: KHA



CITY OF MARGATE, FLORIDA  
DEPARTMENT OF ENVIRONMENTAL  
AND ENGINEERING SERVICES

**TYPICAL CONNECTION TO  
EXISTING MAIN**

**G-15**