



SECTION A-A

NOTES:

1. CONCRETE SLAB TO BE DESIGNED BY ENGINEER OF RECORD.
2. EXTEND CONCRETE SLAB UNTIL COVER EXCEEDS 30 INCHES FOR DIP OR 36 INCHES FOR PVC.
3. CONCRETE TO BE 3,000 PSI MINIMUM.
4. THIS DETAIL TO BE USED ONLY UPON WRITTEN APPROVAL FROM THE CITY.

DATE: 03/24

DRAWN: KHA



CITY OF MARGATE, FLORIDA  
DEPARTMENT OF ENVIRONMENTAL  
AND ENGINEERING SERVICES

**CONCRETE SLAB OVER  
SHALLOW PIPELINES**

**G-25**