



**NOTES:**

1. LOCATE BOX 12" OUTSIDE OF STREET R/W LINE.
2. CITY RESPONSIBILITY ENDS AT CUSTOMER SIDE OF METER.
3. ALL METERS AND METER SPUDS UP TO 1" SHALL BE FURNISHED AND INSTALLED BY THE CITY (ALL OTHER WORK BY CUSTOMER).
4. ALL STRUCTURES TO BE TRAFFIC BEARING TYPE.
5. CURVE IN SERVICE LINE SHALL BE AS CLOSE TO METER BOX AS PRACTICAL, WITH A MINIMUM RADIUS OF 14" FOR 1" TUBING AND 21" FOR 2" TUBING. 5/8" METERS SHALL HAVE A 1" SERVICE LINE.
6. METER SHALL BE CENTERED IN BOX DIRECTLY UNDER THE ACCESS LID. BALL VALVE AND BOTH METERS COUPLINGS SHALL BE VISIBLE IN THE METER BOX.
7. METER, METER BOX, AND SPUD TO BE PROVIDED BY THE CITY.



DATE: 08/24

DRAWN: KHA

CITY OF MARGATE, FLORIDA  
DEPARTMENT OF ENVIRONMENTAL  
AND ENGINEERING SERVICES

**METER INSTALLATION FOR  
5/8" AND 1" METERS**

**W-5**