



NOTES:

1. LOCATE BOX 12" OUTSIDE OF STREET R/W LINE.
2. CITY RESPONSIBILITY ENDS AT CUSTOMER SIDE OF METER.
3. ALL METERS AND CITY SIDE FLANGE UP TO 2" SHALL BE FURNISHED AND INSTALLED BY THE CITY (ALL OTHER WORK BY CUSTOMER).
4. ALL STRUCTURES TO BE TRAFFIC BEARING TYPE.
5. CURVE IN SERVICE LINE SHALL BE AS CLOSE TO METER BOX AS PRACTICAL, WITH A MINIMUM RADIUS OF 21" FOR 2" TUBING.
6. METER SHALL BE CENTERED IN BOX DIRECTLY UNDER THE ACCESS LID.
7. BYPASS SIZE SHALL ACCOMMODATE EXISTING FLOW RATE FROM BYPASSED LINE.
8. SUBMIT METER BOX CONSTRUCTION AND PIPING DETAILS FOR APPROVAL.
9. VALVES SHALL BE BALL VALVES W/ LOCK WINGS.

DATE: 08/24

DRAWN: KHA



CITY OF MARGATE, FLORIDA  
DEPARTMENT OF ENVIRONMENTAL  
AND ENGINEERING SERVICES

**METER INSTALLATION FOR  
1 1/2" AND 2" METERS**

**W-6**