



NOTES:

1. LOCATE BOX 12" OUTSIDE OF STREET R/W LINE.
2. CITY RESPONSIBILITY ENDS AT CUSTOMER SIDE OF METER.
3. ALL METERS INSTALLED BY CITY (INCLUDES METER BOX AND SPUD).
4. ALL STRUCTURES TO BE TRAFFIC BEARING TYPE.
5. CURVE IN SERVICE LINE SHALL BE AS CLOSE TO METER BOX AS PRACTICAL, WITH A MINIMUM RADIUS OF 21" FOR 2" TUBING.
6. METER SHALL BE CENTERED IN BOX DIRECTLY UNDER THE ACCESS LID. BALL VALVE AND METER COUPLINGS SHALL BE VISIBLE INSIDE THE METER BOX.
7. DUAL CHECK ON SINGLE FAMILY HOUSE METERS ONLY. ALL OTHER METERS TO HAVE DOWNSTREAM ABOVE GROUND BACK FLOW PREVENTER.

DATE: 08/24

DRAWN: KHA



CITY OF MARGATE, FLORIDA
DEPARTMENT OF ENVIRONMENTAL
AND ENGINEERING SERVICES

**DOUBLE METER
BOX INSTALLATION**

W-7