



NOTES:

1. CITY OF MARGATE RESPONSIBILITY ENDS AFTER THE METER AND BEFORE THE SECOND RESILIENT SEAT GATE VALVE ON BYPASS LINE.
2. ALL ABOVE GRADE D.I.P. PIPING SHALL BE CLASS 53.
3. BOLLARDS SHALL BE SPACED EVENLY APART AS SHOWN ABOVE AND PER DETAIL G-24. CHAIN SHALL BE LOOPED THROUGH EYELETS CAST IN CONCRETE TOP.
4. USE 45° BENDS WHEN WORKING IS NOT LIMITED.
5. BYPASS SHALL BE SAME IN SIZE AND MATERIAL AS THE METER ASSEMBLY SERVICE LINE
6. SUBMIT PIPING DETAILS FOR APPROVAL
7. METERS LARGER THAN 2" SHALL BE FURNISHED BY THE CITY (ALL OTHER WORK BY CUSTOMERS). ALL METERS TO BE PAID FOR BY OWNER.

DATE: 08/24

DRAWN: KHA



CITY OF MARGATE, FLORIDA
DEPARTMENT OF ENVIRONMENTAL
AND ENGINEERING SERVICES

**METER INSTALLATION FOR
METERS LARGER THAN 2"
(ABOVE GROUND)**

W-8