



NOTES:

1. PIPE JOINT COMPOUND SHALL BE APPLIED TO MALE THREADS ONLY.
2. USE RESTRAINED JOINT PIPE.
3. 2" TAP IN BOTTOM OF PLUG.
4. IN GRASS AREAS USE CONCRETE COLLARS 6" THICK, IN ASPHALT, NO CONCRETE COLLAR IS REQUIRED.

DATE: 08/24

DRAWN: KHA



CITY OF MARGATE, FLORIDA
DEPARTMENT OF ENVIRONMENTAL
AND ENGINEERING SERVICES

**TERMINAL BLOW-OFF
ASSEMBLY**

W-14