



NOTE:

1. PLACE ONE (1) BLUE RAISED PAVEMENT MARKER ADJACENT TO ALL VALVES. WHEN VALVE IS NOT LOCATED IN PAVEMENT PLACE ONE (1) BLUE RAISED PAVEMENT MARKER IN ADJACENT ROADWAY.
2. OPERATOR EXTENSION SHAFT SHALL BE PROVIDED WHEN OPERATING NUT IS MORE THAN 24" BELOW TOP OF VALVE BOX.
3. PVC PIPE AND DUCTILE IRON PIPE ARE ACCEPTABLE FOR VALVE BOX RISER WITH PROPER BEDDING.

DATE: 07/25

DRAWN: KHA



CITY OF MARGATE, FLORIDA
DEPARTMENT OF ENVIRONMENTAL
AND ENGINEERING SERVICES

VERTICAL GATE VALVE

W-15