

SEE VALVE COLLAR AND IDENTIFICATION
MARKER DETAIL. CONCRETE VALVE
COLLAR ON GRASS AREAS ONLY

FINISH GRADE

ADJ. SCREW TYPE CAST IRON VALVE
BOX UPPER SECTION

12" MAX.
6" MIN.

VALVE SIZE AND END AS
SPECIFIED OR AS SHOWN
ON DWGS.

CAST IRON VALVE BOX
LOWER SECTION

GEAR OPERATOR

UNDISTURBED EARTH

DATE: 08/24

DRAWN: KHA



CITY OF MARGATE, FLORIDA
DEPARTMENT OF ENVIRONMENTAL
AND ENGINEERING SERVICES

**BUTTERFLY VALVE WITH
GEAR OPERATOR**

W-16