



NOTES:

1. SINGLE SERVICE CONNECTIONS SHALL USE 6" PVC MINIMUM DIAMETER PIPE AND FITTINGS.
2. DOUBLE SERVICE CONNECTIONS SHALL USE 6" PVC MINIMUM DIAMETER PIPE AND FITTINGS.
3. USE WYE SERVICE CONNECTION WHERE INVERT OF SEWER IS LESS THAN 7'-0" DEEP.
4. SINGLE SERVICE CONNECTIONS BELOW 12' DEPTH SHALL BE C-900 PVC UNTIL LESS THAN 12 FOOT DEPTH.
5. WHERE BELL OF WYE AND SPIGOT OF EXISTING MAIN ARE NOT COMPATIBLE, USE A SECOND FLEXIBLE COUPLING.
6. RIGID COUPLINGS MAY BE USED IN LIEU OF FLEXIBLE COUPLINGS.
7. MAINTAIN 36" MINIMUM COVER FROM TOP OF SERVICE TO FINISH GRADE; WHERE NOT TECHNICALLY FEASIBLE CONTACT CITY UTILITY DEPARTMENT.
8. PVC SERVICES SHALL BE INSTALLED IN ACCORDANCE WITH MINIMUM STANDARDS OF THE UNI-BELL HANDBOOK OF PVC PIPE DESIGN AND CONSTRUCTION, LATEST EDITION.
9. PIPE AND FITTINGS SHALL BE PVC SDR-35.

DATE: 08/24

DRAWN: KHA



CITY OF MARGATE, FLORIDA
DEPARTMENT OF ENVIRONMENTAL
AND ENGINEERING SERVICES

**RISER SERVICE
CONNECTION**

WW-2