



NOTES:

1. BERM TO BE CONSTRUCTED OF SUITABLE FILL MATERIAL. NO MUCK OR OPEN GRADED SILICA (SUGAR) SAND WILL BE ACCEPTABLE.
2. BERM TO BE COMPACTED TO 92% DENSITY AND SODDED OR STABILIZED IN AN APPROVED METHOD TO PREVENT EROSION.
3. TOP OF BERM OR WALL TO BE CONSTRUCTED TO A MINIMUM ELEVATION EQUAL TO THE PROJECTED 25 YEAR EVENT STORM.
4. RETAINING WALL AND FOOTER TO BE DESIGNED BY A PROFESSIONAL ENGINEER LICENSED IN THE STATE OF FLORIDA. SHAPE AND DESIGN TO BE DETERMINED BY ENGINEER OF RECORD. ALL ASPECTS OF RETAINING WALL, INCLUDING ENTIRE FOOTER/FOUNDATION, SHALL BE SITUATED COMPLETELY WITHIN PRIVATE PROPERTY.

DATE: 12/24

DRAWN: KHA



CITY OF MARGATE, FLORIDA
DEPARTMENT OF ENVIRONMENTAL
AND ENGINEERING SERVICES

**TYPICAL PERIMETER
BERM DETAILS**

G-28