



#### PAVING LEGEND



MINIMUM 3/4" LIFTS EACH FOR A TOTAL OF 1-1/2" ASPHALT SURFACE TYPE SP-9.5 OR APPROVED EQUAL. A TACK COAT SHALL BE APPLIED BETWEEN LIFTS PER FDOT STANDARDS, IF PLACED IN (2) TWO LIFTS.



MINIMUM 8" FOR ROAD AND 6" FOR PARKING LOTS LIMEROCK BASE COMPACTED IN 1 LIFT WITH MINIMUM LBR OF 100 TO 98% MAX. DENSITY PER AASHTO T-180. A PRIME COAT SHALL BE UNIFORMLY APPLIED TO THE SURFACE OF THE FINISHED ROCK BASED UPON RATES PER FDOT STANDARDS.



12" THICK SUBGRADE COMPACTED AND STABILIZED WITH MINIMUM DESIGN LBR OF 40 COMPACTED TO AT LEAST 98% OF MAXIMUM DRY DENSITY (AASHTO T-180)

#### PAVEMENT CROSS-SECTION

NTS

DATE: 12/24

DRAWN: KHA



CITY OF MARGATE, FLORIDA  
DEPARTMENT OF ENVIRONMENTAL  
AND ENGINEERING SERVICES

**PAVEMENT CROSS-SECTION**

**G-35**